

EC-CERTIFICATE OF CONSTANCY OF PERFORMANCE

1415-CPR-41-(C-2/2016)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Smoke and heat control system, Smoke duct sections

Galvanized steel smoke and heat exhaust ventilation system

| | |
|----------------------|--|
| Fire resistance, min | E ₆₀₀ 120 h _o /v _e -1000 |
| Dimensions | - quadrangle cross-section: 1250 × 1000 mm (width × height) - circular cross-section: Ø560 mm |

relates to a construction product, which has the above performance and the following intended use

Smoke control and Fire safety

and produced by

KGB-AIR Légtechnika Gyártó Kft.

H-7200 Dombóvár, Köztársaság u. 10. N. épület., Hungary

and produced in the manufacturing plant

KGB-AIR Légtechnika Gyártó Kft.

H-7200 Dombóvár, Köztársaság u. 10. N. épület., Hungary


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard **EN 12101-7:2011** under system (1) are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 08.02.2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Dated at Szentendre, 08th February 2016





Pataki Erika
Head of Certification Office
Certification Office
of ÉMI Non-profit Ltd.